

07919 RFC 16-11-2007 Engineering Certificate



Robert F Colefax
MIE Aust NPER RPEQ
Mob 0409 482970

Heath P Rodgers
MIE Aust RPEQ
Mob 0418 692087

The Workers Club
124 Spence Street
PO Box 1769
Cairns Qld 4870
crce@bigpond.com

Phone 07 40 519466
Fax 07 40 519477

ABN: 73 966 299 314

COLEFAX RODGERS
CONSULTING ENGINEERS

Kuranda Amphitheatre Society Incorporated

[Contact Kuranda Amphitheatre For More Information](#)

To Whom It May Concern:

RE: Proposed **Lighting / Equipment Support off Roof Frame**
At **Kuranda Amphitheatre, Barron Falls Road, Kuranda**

We, being "Professional Engineers", hereby certify that we are responsible for the structural design check of the roof frame to carry the loading as described below.

We certify that up to 3 Tonnes of equipment can be hung off each roof truss with attachment to be adjacent to truss bottom chord nodes. The structure has been checked for compliance with the relevant clauses of the Building Code of Australia, and the relevant Australian Standards and Codes, in particular, the following:

AS 1170 parts 0, 1 and 2, the Loading Codes

AS 4100 – Steel Structures

AS 4600 – Cold Formed Steel Structures

Yours faithfully

COLEFAX ASSOCIATES CONSULTING ENGINEERS

A handwritten signature in black ink, appearing to read 'R Colefax', is positioned below the company name.

Robert F Colefax

MIE Aust, NPER, RPEQ